

Submittal Checklist



Engineering and Development Services 14455 W. Van Buren Street, Ste D101, Goodyear, AZ 85338 (623) 932-3004

Gas Line Permit

This checklist has been provided to assist the applicant in assembling documentation needed for a complete submittal. All plans shall be clear and readable, drawn to scale (1/4" per Ft preferred), landscape orientation, and on appropriate size paper as indicated below. Only complete submittals will be accepted for plan review. Please contact Engineering and Development Services with questions regarding the required materials.

- ☐ Completed Building Permit Application – Digital signatures will not be accepted
- ☐ Two copies of a plot/site plan (Minimum 8½" X11", maximum 24"X36") detailing the following:
 - ☐ Location and lengths of all existing gas piping and BTU rating of all existing appliances shall be required if the new installation affects the existing system.
 - ☐ BTU rating for each gas appliance to be installed
 - ☐ Size of gas piping (main and branch lines) to include all piping when it affects the existing system.
 - ☐ Specify type of material for gas piping (metallic, plastic, etc.)
 - ☐ Specify depth if below grade installation. (12" metallic, 18" PE) Below grade PE requires insulated number 18 tracer wire to terminate at each end.
 - ☐ Specify if the gas system is medium pressure. Indicate the location of the approved regulator.
- ☐ Completed Application Checklist (This form)
- ☐ Fees: \$35.00

Note: Gas piping under a concrete slab is to be sleeved and extended a minimum of 12" beyond slab boundaries. For island scenarios, use detail below (This alternate installation method is not approved for LP gas):

